

Town of Plainville
Building Department
Propane Tank Locations for Review

Homeowners & contractors: Identify location of proposed propane installation

Propane tanks shall be located per NFPA 58, Storage & Handling of Liquefied Petroleum Gases

Type of Tank	Location of Filling Connection & Vent Valve from Direct Vents, Ignition Sources, Air Intakes, Openings in Building
DOT Containers filled on site	10 feet from ignition source (direct vents, air conditioners, mechanical air intakes) 3 feet from opening in building (exhaust fan, crawl space, windows)
DOT Containers NOT filled on site	5 foot from relief valve in any direction (source of ignition, direct vents, mechanical air intakes)
ASME Containers (above ground)	Less than 125 gal. WC: 10 feet from ignition sources for 125-500 gal. WC: 10 feet from ignition sources, building/property lines, direct vents 501-2000 gal. WC: 25 feet from buildings, property lines
ASME Containers (below ground) Relief valve fill connections	10 feet from property lines, ignition sources, openings, direct vents

Please show detailed location and dimensions to window openings, direct vent appliance, hatchway, & ignition sources:

Project Address:

Contractor:

Approval By:

Homeowner:

Date: